



UL1994-listed by Underwriters Laboratories: Photoluminescent Egress Path Marking System Component	Photoluminescent NO EXIT Sign, Rigid PVC, self-adhesive Item-No: 600098HIF
---	--

Item-No:	Description:	Dimensions:
600098HIF	<p>Photoluminescent sign, placed on doors along the egress path that lead to dead ends (e.g., mechanical rooms, storage closets, etc.)</p> <p>NO EXIT in color RED on photoluminescent yellowish rigid PVC background.</p> <p>Sans serif font with the word EXIT in 1-inch letter height and the word NO centered above in 2-inch letter height.</p> <p>NO EXIT sign, Rigid PVC, with adhesive backing</p>  <p>UL Model-Number: CC-RIGIDX</p>	<p>5-inch x 5-inch</p> 

Typical Use

Photoluminescent Egress Path Marking Component

- ✓ In compliance with IBC Section 1024 'Luminous Egress Path Markings'
- ✓ In compliance with NFPA 101-*Life Safety Code* Section 7.2.2.5.5 'Exit Stair Path Markings'
- ✓ UL1994-listed by Underwriters Laboratories, Inc. to 'Standard for Luminous Egress Path Marking Systems' as **Model: CC-RIGIDX**
- ✓ **Activation by LED and Fluorescent Lighting**

Ideal as

- Signage on doors that lead to dead ends (such as mechanical rooms and storage closets)