



UL1994-listed by Underwriters Laboratories: Photoluminescent Egress Path Marking System Component	Photoluminescent NO EXIT Sign, Aluminum, self-adhesive Item-No: 600098IBC
---	---

Item-No:	Description:	Dimensions:
600098IBC	<p>Photoluminescent sign, placed on doors along the egress path that lead to dead ends (e.g., mechanical rooms, storage closets, etc.)</p> <p>NO EXIT in color RED (sans serif font) on photoluminescent yellowish ALUMINUM background with foamy adhesive backing</p>  <p>UL Model-Number: CC-ALU with NYC Local Law 141 required UL1994-Labeling</p> <p>and</p> <p>NYC Local Law 26; RS 6-1 compliant Labeling: MEA 302-05-M BR: 36-9-6 UV</p> <p>The NO EXIT sign is RED: Because per NYC requirements, those signs that are informational but <u>do not direct persons to egress routes</u> shall have the non-photoluminescent portions in <u>any color except green</u>.</p>	<p>5-inch x 5-inch</p> 

Typical Use

Photoluminescent Egress Path Marking Component

- ✓ In compliance with IBC Section 1024 'Luminous Egress Path Markings'
- ✓ In compliance with NFPA 101-*Life Safety Code* Section 7.2.2.5.5 'Exit Stair Path Markings'
- ✓ UL1994-listed by Underwriters Laboratories, Inc. to 'Standard for Luminous Egress Path Marking Systems' as **Model: CC-ALU**
- ✓ **Activation by LED and Fluorescent Lighting**
- ✓ NYC Local Law 141 compliant – *with NYC required IBC Labeling*
- ✓ NYC Local Law 26 – RS 6-1 compliant – *with NYC required MEA Labeling*
- ✓ MEA certified: MEA 302-05-M BR: 36-9-6 UV

Ideal as

- Signage on doors that lead to dead ends (such as mechanical rooms and storage closets)