






UL1994-listed by Underwriters Laboratories: Photoluminescent Egress Path Marking System Component	<b>Obstacle Marking</b>  <b>Item-Nos.: 82-44151 + 82-44151L</b>
---	---

Item-No:	Description:	Dimensions:
	Used to mark:  <b>Obstacles at or below 6 feet 6 inches</b> in height and <b>projecting more than 4 inches</b> into the egress path. See 2009 IBC Sec. 1024.2.5	
82-44151	Photoluminescent/ Black alternating Obstacle Marking; self-adhesive. 1-inch x <b>82 feet</b> per Roll	1-inch x 82 foot  1-inch x 164 foot
82-44151L	1-inch x <b>164 feet</b> per Roll   UL Model-Number: <b>CC-TAPE</b>  Ideal on a large variety of Obstacles, such as: pipes, fire hoses, electric circuit boxes, overhead projections. With NYC Local Law 141 required Labeling imprinted. <div style="display: flex; justify-content: space-around; margin-top: 10px;">   </div>	  

## Typical Use

### Photoluminescent Egress Path Marking Component

- ✓ In compliance with IBC Section 1024 'Luminous Egress Path Markings' which requires Obstacle Markings **no less than 1 inch (25 mm) in width.**
- ✓ In compliance with NFPA 101-*Life Safety Code* Section 7.2.2.5.5 'Exit Stair Path Markings' that requires Obstacle Markings of **no less than 1 inch (25 mm).**
- ✓ In compliance with NYC Local Law 141.
- ✓ UL1994-listed by Underwriters Laboratories, Inc. to 'Standard for Luminous Egress Path Marking Systems' as Model: CC-TAPE Photoluminescent/ Black: UL1994-Listing obtained at 1" strip width.
- ✓ **Activation by LED and Fluorescent Lighting**

### Photoluminescent/ Black Obstacle Marking Tape ideal

- On Obstacles at or below 6 feet 6 inches (78") in height, projecting more than 4 inches into the egress path