







UL1994-listed by Underwriters Laboratories: Photoluminescent Egress Path Marking System Component	<p>Door Handle Backings Item-Nos.: 82-60204 + 82-7748 + 82-60107IBC</p> <p>Push Bar Marking Item-Nos.: 82-40708 + 82-40708L</p>
---	---

Item-No:	Description:	Dimensions:
82-60204	Door Handle Backings - used to mark: <ul style="list-style-type: none"> • Door Hardware with no less than 16 square inches of photoluminescent material. This marking shall be located behind, immediately adjacent to or on the door handle and/or escutcheon. See 2009 IBC Sec. 1024.2.6.2 Photoluminescent Polyester Tape Sticker SQUARE, self-adhesive. UL-Model: CC-TAPE	4-inch x 4-inch 
82-7748	Photoluminescent Rigid PVC SQUARE, self-adhesive UL-Model: CC-RIGIDX	
82-60107IBC	Photoluminescent Aluminum SQUARE, self-adhesive with UL1994-Labeling and NYC MEA Labeling UL-Model: CC-ALU	
82-40708	Push Bar Tape – used to mark: <ul style="list-style-type: none"> • Panic Bars with no less than 1 inch wide photoluminescent tape for the entire length of the actuating bar or touchpad. See 2009 IBC Sec. 1024.2.6.2 Polyester Thin Film, self-adhesive. UL Model-Number: CC-TAPE	1-inch wide Roll 
82-40708L	1-inch x 82 feet per Roll: all-photoluminescent	1-inch x 164 foot Roll OPTIONAL: with NYC Labeling
82-40708LNYC	1-inch x 164 feet per Roll: all-photoluminescent  PUSH BAR TAPE also available with NYC Local Law 141 required Labeling: 1-inch x 164 feet per Roll	

Typical Use

Photoluminescent Egress Path Marking Component

- ✓ In compliance with IBC Section 1024 'Luminous Egress Path Markings'
- ✓ In compliance with NFPA 101-*Life Safety Code* Section 7.2.2.5.5 'Exit Stair Path Markings'
- ✓ In compliance with NYC Local Law 141
- ✓ UL1994-listed by Underwriters Laboratories, Inc. to 'Standard for Luminous Egress Path Marking Systems'
- ✓ Photoluminescent UL1994-Listing obtained at half-inch (= 1/2") strip width!!
- ✓ **Activation by LED and Fluorescent lighting**

Photoluminescent markings ideal

- Door Handle Backing on Vestibule and final exit doors
- Push Bar marking on Vestibule and final exit doors