


















UL1994-listed by Underwriters Laboratories: Photoluminescent Egress Path Marking System Component	<b>Photoluminescent Directional Signs +          Stairway Identification Signage</b>  <b>Multiple Item-Numbers</b>
---	--

Item-No:	Description:	Dimensions:
<b>PREFERRED:</b> <b>86-18128</b> CC-RIGIDX          <b>OPTIONAL:</b> <b>86-18127</b> <b>CC-ALU</b>	<p>Floor Identification Sign (per IBC) AKA. Stairway Identification Sign (per NFPA 101). Provided at each floor landing in exit enclosures. Always custom-made with text to building needs. Black plotter-cut or digital print lettering on photoluminescent background. Where required, the Floor Level (e.g., B, 1, 7) as raised text with Braille underneath.</p> <p>Letters designating the Stair Enclosure [here: STAIR 2] shall be a minimum of 1-1/2 inch high.</p> <p>The Floor Level [here: 7] shall be minimum 5 inches tall.</p> <p>All other lettering and numbers shall be a minimum of 1-inch tall.</p>  <p><b>LISTED</b> Signs typically made with Rigid PVC: CC-RIGIDX</p> <p><b>Aluminum as Optional base material: CC-ALU</b></p>	<p>Minimum 18-inches tall x 12-inches wide</p> 
86-42867F          86-42947F	<p>Emergency Exit Symbol signs, made from Aluminum with photoluminescent surface/ contrast green with foamy adhesive backing. Installed on doors through which occupants within an exit enclosure must pass in order to complete the exit path. Those doors shall be identified by a low-location emergency exit symbol complying with NFPA 170. To be mounted <u>on the door</u>, centered horizontally, with the <u>top of the symbol no higher than 18 inches</u> above the finished floor.</p>  <p>Man to the Right, self-adhesive</p>  <p>Man to the Left, self-adhesive</p>  <p><b>LISTED</b> UL Model-Number: <b>CC-ALU</b></p>	 <p>5-3/4" x 5-3/4"</p> <p>5-3/4" x 5-3/4"</p>

Item-No:	Description:	Dimensions:
86-43027F	 <p>Straight Arrow, self-adhesive</p>	5-3/4" x 5-3/4"
86-43107F	 <p>Diagonal Arrow, self-adhesive</p>	5-3/4" x 5-3/4"
<p><b>OPTION: If a larger Sign Size is desired, select these:</b></p> <ol style="list-style-type: none"> <li>1) Select ONLY a Running Man on doors through which occupants within an exit enclosure must pass in order to complete the exit path. Mount <u>on the door</u>, centered horizontally, with the <u>top of the symbol no higher than 18 inches</u> above the finished floor</li> <li>2) Select a Man Running AND an Arrow if used as Directional signs and installed inside the exit enclosure on main landing to show the direction of travel up from sub-basements or down from higher floors. Installed on the wall, such that sign is visible for evacuees already inside the staircase, as well as for occupants just entering the staircase.</li> </ol> <p>Made from Aluminum with photoluminescent surface/ contrast green with foamy adhesive backing.</p>		
86-42887F	 <p>Man to the Right, self-adhesive</p>	7-7/8" x 7-7/8"
86-42967F	 <p>Man to the Left, self-adhesive</p>	7-7/8" x 7-7/8"
86-43047F	 <p>Straight Arrow, self-adhesive</p>	7-7/8" x 7-7/8"
86-43127F	 <p>Diagonal Arrow, self-adhesive</p>	7-7/8" x 7-7/8"



UL Model-Number: **CC-ALU**

Item-No:	Description:	Dimensions:
86-60117IBC	<p>Directional signs, made from Aluminum with photoluminescent surface/contrast green with foamy adhesive backing. Installed inside the exit enclosure on main landing to show the direction of travel up from sub-basements or down from higher floors.</p> <p>Installed on the wall, such that sign is visible for evacuees already inside the staircase, as well as for occupants just entering the staircase.</p>  <p>Aluminum, self-adhesive</p>	4.5" tall x 8" tall
86-60127IBC	  <p>LISTED UL Model-Number: <b>CC-ALU</b></p> <p>Optionally available:</p> 	

### Typical Use

**Photoluminescent Egress Path Marking Component**

- ✓ In compliance with IBC Section 1024 'Luminous Egress Path Markings'
- ✓ In compliance with NFPA 101-*Life Safety Code* Section 7.2.2.5.5 'Exit Stair Path Markings'
- ✓ UL1994-listed by Underwriters Laboratories, Inc. to 'Standard for Luminous Egress Path Marking Systems' as **Model: CC-ALU** for NFPA 170 *Standard for Fire Safety and Emergency Symbols* compliant 'Man Running' and 'Arrow' directional signage  
**Model: CC-RIGID** for Stairway Identification / Floor Identification signage
- ✓ **Activation by LED and Fluorescent Lighting**

Ideal as

- Signage inside exit enclosures